

USV-Serie HEAM 25-125kVA / 50-800kVA

- 1. Wirkungsgrad in Abhängigkeit der Auslastung
- 2. Eingang-Leistungsfaktor in Abhängigkeit der Auslastung

1. HEAM0025-0800 UPS efficiency curve per load (10%~100%)



Load	10%	15%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Efficiency (%)	92.5	93.00	94.33	95.6	96,2	96,2	96	95.8	95.7	95.6	95.4

2. Eingangs-Leistungsfaktor in Abhängigkeit der Auslastung

PF with RCD load

RCD Load	PF		
	R	S	T
10%	0.977	0.976	0.982
20%	0.988	0.988	0.987
30%	0.994	0.993	0.993
40%	0.997	0.996	0.997
50%	0.998	0.997	0.997
60%	0.998	0.997	0.997
70%	0.999	0.998	0.998
80%	0.999	0.998	0.998
90%	0.999	0.998	0.998
100%	0.999	0.999	0.999